

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3625-1542:100 Page 1 of 1

CATEGORY: Exit Door Accessories

LISTEE: Custom Hardware Manufacturing Inc., 2600 Kindustry Park Road, Keokuk, IA 52632
Contact: Mark Kemp (319) 524-7119

DESIGN: Model Smart touch special locking arrangement sense bar. This unit is capacitively operated "dummy" push bars that have no latching mechanism but is provided with an electronic sensing/switching assembly that will activate an electromagnetic lock system. Unit is intended for used with separately listed Securitron Magnalock's Model 62 series lock (CSFM Listing No. 3774-0923:101) and BPS Series power supply. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as an accessory to separately listed electromagnetic locks for use on non-rated door assemblies to prevent unauthorized entry when the building is not occupied. Authority having jurisdiction shall be consulted prior to installation.

02-28-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 18, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**